

Building ID	Sample Date	Fixture Type	Sample Type	Concentration (ug/L)	Notes
Center Elementary	10/19/17	S - Sink	First Draw	8.58	need to flush for 60 seconds before use
Center Elementary	10/19/17	S - Sink	Flush	< 2.00	need to flush for 60 seconds before use
Center Elementary	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Center Elementary	10/19/17	DF - Drinking Fountain	Flush	< 2.00	
Center Elementary	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Center Elementary	10/19/17	DF - Drinking Fountain	Flush	< 2.00	
Center Elementary	10/19/17	DF - Drinking Fountain	First Draw	9.10	need to flush for 60 seconds before use
Center Elementary	10/19/17	DF - Drinking Fountain	Flush	3.44	need to flush for 60 seconds before use
Center Elementary	10/19/17	DF - Drinking Fountain	First Draw	42.39	need to flush for 60 seconds before use
Center Elementary	10/19/17	DF - Drinking Fountain	Flush	2.29	need to flush for 60 seconds before use
Center Elementary	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Center Elementary	10/19/17	DF - Drinking Fountain	Flush	< 2.00	
Center Elementary	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Center Elementary	10/19/17	DF - Drinking Fountain	Flush	< 2.00	
Center Elementary	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Center Elementary	10/19/17	DF - Drinking Fountain	Flush	< 2.00	
Center Elementary	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Center Elementary	10/19/17	DF - Drinking Fountain	Flush	< 2.00	
Center Elementary	10/19/17	DF - Drinking Fountain	First Draw	< 2.00	
Center Elementary	10/19/17	DF - Drinking Fountain	Flush	< 2.00	