

Building ID	Sample Date	Fixture Type	Sample Type	Concentration (ug/L)	Notes
Jones Farrar Magnet School	10/17/17	S - Sink	First Draw	5.29	need to flush for 60 seconds before use
Jones Farrar Magnet School	10/17/17	S - Sink	Flush	< 2.00	need to flush for 60 seconds before use
Jones Farrar Magnet School	10/17/17	DF - Drinking Fountain	First Draw	< 2.00	
Jones Farrar Magnet School	10/17/17	DF - Drinking Fountain	Flush	< 2.00	
Jones Farrar Magnet School	10/17/17	DF - Drinking Fountain	First Draw	< 2.00	
Jones Farrar Magnet School	10/17/17	DF - Drinking Fountain	Flush	< 2.00	
Jones Farrar Magnet School	10/17/17	DF - Drinking Fountain	First Draw	< 2.00	
Jones Farrar Magnet School	10/17/17	DF - Drinking Fountain	Flush	< 2.00	
Jones Farrar Magnet School	10/17/17	DF - Drinking Fountain	First Draw	< 2.00	
Jones Farrar Magnet School	10/17/17	DF - Drinking Fountain	Flush	< 2.00	
Jones Farrar Magnet School	10/17/17	DF - Drinking Fountain	First Draw	< 2.00	
Jones Farrar Magnet School	10/17/17	DF - Drinking Fountain	Flush	< 2.00	