

Building ID	Sample Date	Fixture Type	Sample Type	Concentration (ug/L)	Notes
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	First Draw	83.39	disabled
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	Flush	37.72	disabled
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	First Draw	23.82	disabled
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	Flush	7.59	disabled
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	First Draw	31.44	disabled
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	Flush	13.03	disabled
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	First Draw	2.03	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	Flush	4.99	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	First Draw	< 2.00	
Carl Sandburg Middle School	10/5/17	DF - Drinking Fountain	Flush	< 2.00	
Carl Sandburg Middle School	10/5/17	S - Sink	First Draw	< 2.00	
Carl Sandburg Middle School	10/5/17	S - Sink	Flush	2.45	